



**Add value.
Inspire trust.**

TÜV SÜD PSB Pte Ltd - 15 International Business Park, TÜV SÜD @ IBP, Singapore 609937

PT. TOILON INDONESIA
Jl. Raya Serang Km. 16,8, Talaga, Cikupa,
Tangerang Regency
Banten 15710, Indonesia

Attention to: Mr. Je Hwan Young

Your reference/letter of	Our reference/Name	Tel.-Extension/E-mail	Fax-Extension	Date	Page
-	7191346257 / Ye Wint Aung	+65 6865 3772 / wint-aung.ye@tuvsud.com	+65 6862 1433	16 January 2025	1 of 1

Dear Mr. Je,

Class “0” Classification

References:

1. TÜV SÜD PSB report no.: 7191346257-MEC24/1-YWA dated 07 Jan 2025.
2. TÜV SÜD PSB report no.: 7191346257-MEC24/2-YWA dated 07 Jan 2025.

The result of the test detailed as mentioned in above references demonstrate that the product Brand: “TOILON”, Model: “Thermotech IXPE FR Class O”, Crosslinked Polyolefin foam faced with the reinforced aluminium foil, as tested, complied with the requirements for Class “0”.

*Please note that a valid Certificate of Conformity (COC) is required for Singapore application on regulated fire safety products/materials.

Yours sincerely,

Ye Wint Aung
Senior Associate Engineer
(Fire Testing)
Mechanical Centre

Telephone: +65 6778 7777
Fax No.: +65 6779 7088
www.tuvsud.com/sg

TUV®

TÜV SÜD PSB Pte Ltd
15 International Business Park
TUV SÜD @ IBP, Singapore 609937

Reg. No.: 199002667R